

January 14, 2024 – Report # 24-012 – 6:57 p.m. Occurred on January 14, 2024, between 6:57 p.m. and 8:04 p.m. ALARM SOUNDING-CENTER FOR NANOSCIENCE. An alarm was sounding and when the UMSL Police along with maintenance arrived it was discovered to be caused by a broken water line that was leaking in the building. This was caused by a broken water pipe due to the extreme cold weather. Disposition: Inactive.

