

September 3, 2023 – Report # 23-0245 – 8:58 a.m. Occurred on September 3, 2023, between 8:56 a.m. and 9:46 a.m. FIRE ALARM-OAK HALL. A fire alarm was sounding and evacuation had taken place. The fire department along with the UMSL Police responded and determined that the alarm was caused by a faulty smoke detector. No fire and no injuries. Disposition: Inactive.

